

(E) FH located ~200' from north corner of parcel.

Minimum required fire flow for non-sprinklered structures is 1,500 gpm @ 20 psi for 2 hours.

- LEGEND
- Color: [Red] (E) Fire Hydrant
 - Color: [Green] (G) Greenhouse
 - Color: [Blue] (C) Carport
 - Color: [Purple] (A) ADA Portable Restroom
 - Color: [Orange] (T) Trash Bin
 - Color: [Yellow] (P) Parking
 - Color: [Light Purple] (A) ADA Parking
 - Color: [Light Yellow] (A) ADA Path

CASE: PAR230100
 EXHIBIT: A
 DATE: 1-18-2024
 PLANNER: J.Aparicio

Meeting Comment Agenda Final

THEDA ST

- CARPORT 20X80
- AG BARN 50X20
- TRASH BIN 20X10
- ADA PORTABLE RESTROOM
- PARKING 10X40 GRAVEL
- ADA PARKING 10X12
- ADA PATH GRAVEL



HWY 74

